



NOTES:

1. THE LAST NUMBER IN THE DESIGNATION IS THE CURB FACE (CF) HEIGHT IN INCHES.
2. GUTTER WIDTH, W, IS 24" UNLESS SPECIFIED OTHERWISE.
3. TYPES A, B, AND C SHALL BE CONSTRUCTED FROM PORTLAND CONCRETE CEMENT (P.C.C.) 520-C-2500.
4. ALL EXPOSED CORNERS ON P.C.C. CURBS AND GUTTERS SHALL BE ROUNDED WITH A 1/2" RADIUS.
5. FINISH SHALL BE LIGHT BROOM FINISH, EXCEPT IN THE FLOWLINE, WHICH SHALL HAVE A SMOOTH STEEL TROWEL FINISH.
6. COMPACTION OF NATIVE SUBGRADE SHALL MEET 95%.



CITY OF LAGUNA BEACH PUBLIC WORKS DEPARTMENT

REV.	DATE

P.C.C. CURB AND GUTTER

APPROVED BY:

MARK A. TRESTIK, CITY ENGINEER, R.C.E. 53708

03/29/2022

DATE

STANDARD PLAN

105

1 OF 1