



5" ROLLED CURB

NOTES:

1. GUTTER WIDTH SHALL BE 24" UNLESS SPECIFIED OTHERWISE.
2. ROLLED CURB SHALL BE CONSTRUCTED FROM PORTLAND CONCRETE CEMENT (P.C.C.) 520-C-2500.
3. CURB TRANSITIONS SHALL BE 15 FEET MINIMUM, EACH DIRECTION, FROM NEW CURB TO EXISTING.
4. ALL EXPOSED CORNERS ON P.C.C. CURBS AND GUTTERS SHALL BE ROUNDED WITH A 1/2" RADIUS.
5. FINISH SHALL BE LIGHT BROOM FINISH, EXCEPT IN THE FLOWLINE, WHICH SHALL HAVE A SMOOTH STEEL TROWEL FINISH.
6. COMPACTION OF NATIVE SUBGRADE SHALL MEET 95%.



CITY OF LAGUNA BEACH PUBLIC WORKS DEPARTMENT

REV.	DATE	P.C.C. ROLLED CURB AND GUTTER		STANDARD PLAN
		APPROVED BY:	03/29/2022	106
		MARK A. TRESTIK, CITY ENGINEER, R.C.E. 53708	DATE	1 OF 1